



**THE JHARKHAND STATE COOPERATIVE MILK
PRODUCERS' FEDERATION LTD.**

Near Farmers Training Centre Campus,
Sec-II, H.E.C., Dhurwa, Ranchi – 834004



Ph. no: 0651-2270046 /7544003404/7544003412, website <http://www.jmf.coop>

Date: 26/07/2022

CORRIGENDUM TO TENDER

Tender No. JMF-PI-BMC 2KL-3 KL & 5KL/2022-23/019, Dated. 14 July 2022

Tender detail: “FOR SUPPLY, INSTALLATION & COMMISSIONING OF BULK MILK COOLER (BMC) OF CAPACITY -2KL, 3KL & 5KL WITH HEAT RECOVERY UNIT”

In reference to the aforesaid tender.

THE CORRIGENDUM /AMENDMENT TO BE READ & FOLLOW AS PER BELOW:

Page No/ Clause No as per tender	As per Tender	To be read as
Page No. 18, Clause No. 2.1 of Bulk Milk Cooler Tank:	ISO 5708 Type II (latest version) for 2 milk collections: a) Cooling 50% of first milk collection of its rated capacity in 3 hrs from 35 Deg C to 4 Deg C b) Cooling of 100% of milk volume after 50% of milk is added from second milk collection (average temp 16 Deg C to 4 Deg C) in 1 hrs 30 minutes.	b) Cooling of 100% of milk volume after 50% of milk is added from second milk collection (average temp average temp 10 Deg C to 4 Deg C) in 1 hrs 30 minutes.
Page No. 26, Clause No. 9 of Extra Spare Parts required (To be included in the equipment cost)	Extra Spare Parts required (To be included in the equipment cost)	The spare requirement is to be considered in the price of quoted for each capacity BMCUs

All other details & terms & conditions will remain same. The inconvenience caused is regretted.

Managing Director