



Jharkhand State Cooperative Milk Producers' Federation Ltd.

Near Farmers Training Centre Campus, Sec-II, H.E.C., Dhurwa,
Ranchi – 834004



Ph.: 7544003404/7360035219, website <http://www.jmf.coop>

Date: 27/12/2021

CORRIGENDUM TO TENDER

Tender ref. No: JMF-PP-BULK MILK COOLER (BM-WITH HEAT RECO/2021-22/070,
Dtd. 15.12.2021

Tender detail: “Supply, Installation & Commissioning of Bulk Milk Cooler (BMC)
-2KL With Heat Recovery Unit”

In reference to the aforesaid tender.

**THE CORRIGENDUM /AMENDMENT TO BE READ & FOLLOW AS PER
ENCLOSED ANNEX - I**

All other details & terms & conditions will remain. The inconvenience caused is regretted.

Managing Director

ANNEX- I

CORRIGENDUM TO TENDER

Tender Ref; JMF-PP-BULK MILK COOLER (BM-WITH HEAT RECO/2021-22/070, Dtd. 15.12.2021

Page No/ Clause No as per tender	Current description	To be replaced with
P.8, C 1.5	<p>The prices/ rate quoted should have equipment wise and post warranty Comprehensive Maintenance charges for a period of 2 years with breakup. The terms of comprehensive maintenance shall be as below:</p> <p>i. The period of comprehensive maintenance shall be of two years, post expiry of warranty for the BMC Unit.</p> <p>ii. During the warranty & Maintenance contract period, quarterly inspection visits including servicing of the DG Sets shall be required for which cost of consumables</p>	<p>The prices/ rate quoted should have equipment wise and post warranty maintenance charges for a period of 2 years with breakup. The terms of two years maintenance shall be as below:</p> <p>i. The period of maintenance shall be of two years, post expiry of warranty for the BMC Unit.</p> <p>ii. During the maintenance contract period, quarterly inspection visits including servicing/labour charges of the BMCU, DG Sets and other accessories shall be payable by the supplier, however required</p>

Page No/ Clause No as per tender	Current description	To be replaced with
	<p>shall be payable by JMF but spares (if required) & labour/service charge shall be payable by supplier.</p> <p>iii. Breakdown of the DG set or any other component of unit shall be attended onsite within 24 hours of reporting and defective components/ spares are to be replaced free of cost by the supplier. The service/ labour charges shall also be payable by supplier.</p>	<p>consumables and spares (if any) shall be payable by JMF/ purchaser.</p> <p>iii. Breakdown of the DG set or any other component of unit shall be attended onsite within 24 hours of reporting.</p>
P. 10, C. 5	<p>It is mandatory on the part of the manufacturer to have a service center in the state of Jharkhand. The detailed contact address with land line / cell number should be provided along with the tender document.</p>	<p>It is mandatory on the part of the DG manufacturer to have a DG service center in the state of Jharkhand. The detailed contact address with land line / cell number should be provided along with the tender document.</p>
P. 10, C. 6	<p>The set should be covered under 3 years warranty/guarantee period</p>	<p>The set should be covered under 12 months of comprehensive warranty from the date of successful</p>

Page No/ Clause No as per tender	Current description	To be replaced with
	from the date of successful commissioning.	commissioning of BMCs. During warranty period, apart from service charge the malfunctioned/ defective components and spares are to be replaced free of cost by the supplier.
P. 10, C. 7	It shall be the responsibility of the supplier for getting necessary verification / re-verification of and stamping of weighing scales supplied as per the statutory compliance from W&M offices in various districts of Jharkhand for the warranty as well as post warranty AMC duration.	Clause deleted
P. 10, C .11	In case ISI / BIS certification / empaneled under NDDDB certification is not produced the bid shall be rejected.	In Case BIS certification/ proof of supplying BMCs under NDP or any other project of NDDDB/ affiliation of supplier with NDDDB is not produced by the tenderer, the bid shall be rejected.

Page No/ Clause No as per tender	Current description	To be replaced with
P. 19, C 6.1	<p>The DG set shall be of capacity:</p> <ul style="list-style-type: none"> • 15 KVA Single/Three phase, air or water cooled for 2KL BMC 	<p>The DG set shall be of capacity:</p> <ul style="list-style-type: none"> • 15 KVA Three phase, Water Cooled for 2KL BMC
P. 21, C. 7.9	<p>All equipment (including bought out items) supplied & installed by the contractor shall have a comprehensive warranty of 18 Month from date of commissioning.</p>	<p>All equipment (including bought out items) supplied & installed by the contractor shall have a comprehensive warranty of 12 Month from date of commissioning.</p>
P. 21, C. 7.10	<ul style="list-style-type: none"> • Obligation of BMC Package supplier for providing After Sales Service/ Warranty claims for the bought-out components supplied with BMC package. • One resident service engineer to be posted for 50 BMC is to be posted by the supplier for effective and timely after sales service. 	<ul style="list-style-type: none"> • Obligation of BMC Package supplier for providing After Sales Service/Warranty claims for the bought-out components supplied with BMC package. • One resident service engineer to be posted by the supplier if BMCs supplied to JMF by the supplier (including past supplies) exceeds 50 in numbers.
P. 22, Point 2	<p>For hot water generation only one type of water heating</p>	<p>Clause deleted</p>

Page No/ Clause No as per tender	Current description	To be replaced with
	system is to be selected out of the 3 options given below.	
P. 22, C 8.1	<p>Hot water Generation Unit-Heat recovery Unit with necessary piping</p> <p>“Tank shall be of 200 litre capacity in SS 304, 1.6mm constructions with suitable insulation and outlet with 25mm ball valve”</p>	<p>Hot water generation Unit – Heat recovery Unit with necessary piping</p> <p>“Tank shall be of 200 litre capacity in SS 304 outer cell and SS 316 inner cell, 1.6mm constructions with suitable insulation and outlet with 25mm ball valve”</p>